

CONTROL AND OPERATION OF A DC GRID-BASED WIND POWER GENERATION SYSTEM IN A MICRO GRID

V.Rajitha¹P.Sneha²

M.V.Praveen Reddy

Dr.M.Ramesh

¹Student of B.Tech(EEE)

Associate Professor of EEE

Professor & HOD of EEE

mudugantivenkatapraveenreddy@gmail.com

marpuramesh223@gmail.com

Vaageswari College Of Engineering, Karimnagar

Abstract—This paper presents the design of a dc grid-based wind power generation system in a poultry farm. The proposed system allows flexible operation of multiple parallel-connected wind generators by eliminating the need for voltage and frequency synchronization. A model predictive control algorithm that offers better transient response with respect to the changes in the operating conditions is proposed for the control of the inverters. The design concept is verified through various test scenarios to demonstrate the operational capability of the proposed micro grid when it operates connected to and islanded from the distribution grid, and the results obtained are discussed.

Index Terms—Wind power generation, dc grid, energy management, model predictive control.

I. INTRODUCTION

Poultry farming is the raising of domesticated birds such as chickens and ducks for the purpose of farming meat or eggs for food. To ensure that the poultries remain productive, the poultry farms in Singapore are required to be maintained at a comfortable temperature. Cooling fans, with power ratings of tens of kilowatts, are usually installed to regulate the temperature in the farms [1]–[3]. Besides cooling the farms, the wind energy produced by the cooling fans can be harnessed using wind turbines (WTs) to reduce the farms' demand on the grid. The Singapore government is actively promoting this new concept of harvesting wind energy from electric ventilation fans in poultry farms which has been implemented in many countries around the world [4]. The major difference between the situation in poultry farms and common wind farms is in the wind speed variability. The variability of wind speed in wind farms directly depends on the environmental and weather conditions while the wind speed in poultry farms is generally stable as it is generated by constant-speed ventilation fans. Thus, the generation intermittency issues that affect the reliability of electricity supply and power balance are not prevalent in poultry farm wind energy systems.

In recent years, the research attention on dc grids has been resurging due to technological advancements in power electronics and energy storage devices, and increase in the variety of dc loads and the penetration of dc distributed energy resources (DERs) such as solar photo voltaics and fuel cells.

Many research works on dc micro grids have been conducted to facilitate the integration of various DERs and energy storage systems. In [5], [6], a dc micro grid based wind farm architecture in which each wind energy conversion unit consisting of a matrix converter, a high frequency transformer and a single-phase ac/dc converter is proposed. However, the proposed architecture increases the system complexity as three stages of conversion are required. In [7], a dc micro grid based wind farm architecture in which the WTs are clustered into groups of four

with each group connected to a converter is proposed. However, with the proposed architecture, the failure of one converter will result in all four WTs of the same group to be out of service. The research works conducted in [8]–[10] are focused on the development of different distributed control strategies to coordinate the operation of various DERs and energy storage systems in dc micro grids. These research works aim to overcome the challenge of achieving a decentralized control operation using only local variables. However, the DERs in dc micro grids are strongly coupled to each other and there must be a minimum level of coordination between the DERs and the controllers. Hierarchical control algorithms are incorporated to ensure smooth power transfer between the ac micro grid and the dc micro grid under various operating conditions. However, failure of the bidirectional converter will result in the isolation of the dc micro grid from the ac micro grid.

An alternative solution using a dc grid based distribution network where the ac outputs of the wind generators (WGs) in a poultry farm are rectified to a common voltage at the dc grid is proposed in this paper. The most significant advantage of the proposed system is that only the voltage at the dc grid has to be controlled for parallel operation of several WGs without the need to synchronize the voltage, frequency and phase, thus allowing the WGs to be turned ON or OFF anytime without causing any disruptions.

To increase the controller's robustness against variations in the operating conditions when the micro grid operates in the grid-connected or islanded mode of operation as well as its capability to handle constraints, a model-based model predictive control (MPC) design is proposed in this paper for controlling the inverters. As the micro grid is required to operate stably in different operating conditions, the deployment of MPC for the control of the inverters offers better transient response with respect to the changes in the operating conditions and ensures a more robust micro grid operation. There are some research works on the implementation of MPC for the control of inverters. The research work is, however, focused mainly on the control of inverters for uninterruptible power supplies in standalone operation.

In this paper, the inverters are controlled to track periodic current and voltage references and the control signals have a limited operating range. Under such operating condition, the MPC algorithm is operating close to its operating limits where the constraints will be triggered repetitively. In conventional practices, the control signals are clipped to stay within the constraints, thus the system will operate at the sub-optimal point. This results in inferior performance and increases the steady-state loss. MPC, on the contrary, tends to make the closed-loop system operate near its limits and hence produces far better performance. In these research works, the management of energy is formulated into different multi-objective optimization problems and different MPC strategies are proposed to solve these optimization problems. The scope of this paper is however focused on the application of MPC for the control of inverters.

II. SYSTEM DESCRIPTION AND MODELING

A. System Description

The overall configuration of the proposed dc grid based wind power generation system for the poultry farm is shown in Fig. 1. The system can operate either connected to or islanded from the distribution grid and consists of four 10 kW permanent magnet synchronous generators (PMSGs) which are driven by the variable speed WTs. The PMSG is considered in this paper because it does not require a dc excitation system that will increase the design complexity of the control hardware. The three-phase output of each PMSG is connected to a three-phase converter (i.e., converters A, B, C and D), which operates as a rectifier to regulate the dc output voltage of each PMSG to the desired level at the dc grid. The aggregated power at the dc grid is inverted by two inverters (i.e., inverters 1 and 2) with each rated at 40 kW. Instead of using individual inverter at the output of each WG, the use of two inverters between the dc grid and the ac grid is proposed. This architecture minimizes the need to synchronize the frequency, voltage and phase, reduces the need for multiple inverters at the generation side, and provides the flexibility for the plug and play connection of WGs to the dc grid. The availability of the dc grid will also enable the supply of power to dc loads more efficiently by reducing another ac/dc conversion.

The coordination of the converters and inverters is achieved through a centralized energy management system (EMS). The EMS controls and monitors the power dispatch by each WG and the load power consumption in the micro grid through a centralized server. To prevent excessive circulating currents between the inverters, the inverter output voltages of inverters 1 and 2 are regulated to the same voltage. Through the EMS, the output voltages of inverters 1 and 2 are continuously monitored to ensure that the inverters maintain the same output voltages. The centralized EMS is also responsible for other aspects of power management such as load forecasting, unit commitment, economic dispatch and optimum power flow. Important information such as field measurements from smart meters, transformer tap positions and circuit breaker status are all sent to the centralized server for processing through wire line/wireless communication. During normal operation, the two inverters will share the maximum output from the PMSGs (i.e., each inverter shares 20 kW).

$$P_{wt,opt} = k_{opt}(\omega_{r,opt})^3 \dots \dots \dots (1)$$

$$k_{opt} = \frac{1}{2} C_{p,opt} \rho A \left(\frac{R}{\lambda_{opt}} \right)^3 \quad (2)$$

$$\omega_{r,opt} = \frac{\lambda_{opt} v}{R} \quad (3)$$

where k_{opt} is the optimized constant, $\omega_{r,opt}$ is the WT speed for optimum power generation, $C_{p,opt}$ is the optimum power coefficient of the turbine, ρ is the air density, A is the area swept by the rotor blades, λ_{opt} is the optimum tip speed ratio, v is the wind speed and R is the radius of the blade.




Fig. 1. Overall configuration of the proposed dc grid based wind power generation system in a micro grid.

When one inverter fails to operate or is under maintenance, the other inverter can handle the maximum power output of 40 kW from the PMSGs. Thus the proposed topology offers increased reliability and ensures continuous operation of the wind power generation system when either inverter 1 or inverter 2 is disconnected from operation. An 80 Ah storage battery (SB) is connected to the dc grid through a 40 kW bidirectional dc/dc buck-boost converter to facilitate the charging and discharging operations when the micro grid operates connected to or islanded from the grid. The energy constraints of the SB in the proposed dc grid are determined based on the system-on-a-chip (SOC) limits given by

$$SOC_{min} < SOC \leq SOC_{max} \dots \dots \dots (4)$$

Although the SOC of the SB cannot be directly measured With the use of a dc grid, the impact of fluctuations between power generation and demand can be reduced as the SB can swiftly come online to regulate the voltage at the dc grid. During off-peak periods when the electricity demand is low, the SB is charged up by the excess power generated by the WTs. Conversely, during peak periods when the electricity demand is high, the SB will supplement the generation of the WTs to the loads.

B. System Operation

When the micro grid is operating connected to the distribution grid, the WTs in the micro grid are responsible for providing local power support to the loads, thus reducing the burden of power delivered from the grid. The SB can be controlled to achieve different demand side management functions such as peak shaving and valley filling depending on the time-of-use of electricity and SOC of the SB.

During islanded operation where the CBs disconnect the micro grid from the distribution grid, the WTs and the SB are only available sources to supply the load demand. The SB can supply for the deficit in real power to maintain the power balance of the micro grid as follows:

$$P_{wt} + P_{sb} = P_{loss} + P_l \dots\dots\dots(5)$$

where P_{wt} is the real power generated by the WTs, P_{sb} is the real power supplied by SB which is subjected to the constraint of the SB maximum power $P_{sb,max}$ that can be delivered during discharging and is given by

$$P_{sb} \leq P_{sb,max} \dots\dots\dots(6)$$

P_{loss} is the system loss, and P_l is the real power that is supplied to the loads.




Fig. 2. Power circuit of a PMSG connected to an ac/dc voltage source converter.

C. AC/DC Converter Modeling

Fig. 2 shows the power circuit consisting of a PMSG which is connected to an ac/dc voltage source converter. The PMSG is modelled as a balanced three-phase ac voltage source e_{sa} , e_{sb} , e_{sc} with series resistance R_s and inductance L_s [30], [31]. As shown in [32], the state equations for the PMSG currents i_{sa} , i_{sb} , i_{sc} and the dc output voltage V_{dc} of the converter can be expressed as follows:

$$L_s \frac{di_s}{dt} = -R_s i_s + e_s - K S V_{dc} \quad (7)$$

$$C \frac{dV_{dc}}{dt} = i_s^T S - I_{dc} \quad (8)$$

Where

$S = S_a S_b S_c T$ is the ac/dc converter switching functions which are defined as

$$S_j = \begin{cases} 1, & S_j \text{ is ON} \\ 0, & S_j \text{ is OFF} \end{cases} \quad \text{for } j = a, b, c \quad (9)$$

D. DC/AC Inverter Modeling

The two 40 kW three-phase dc/ac inverters which connect the dc grid to the point of common coupling (PCC) are identical, and the single-phase representation of the three-phase dc/ac inverter is shown in Fig. 3. To derive a state-space model for the inverter, Kirchhoff’s voltage and current laws are applied to loop i and point x respectively, and the following equations are obtained:

$$L_f \frac{di}{dt} + iR + v_{DG} = uV_{dc} \tag{10}$$

$$i_{DG} = i - i_{C_f} \tag{11}$$

where V_{dc} is the dc grid voltage, u is the control signal, R is the inverter loss, L_f and C_f are the inductance and capacitance of the low-pass (LPF) filter respectively, i_{DG} is the inverter output current, i is the current flowing through L_f , i_{C_f} is the current flowing through C_f , and v_{DG} is the inverter output voltage.




Fig:3. Single-phase representation of the three-phase dc/ac inverter.

During grid-connected operation, the inverters are connected to the distribution grid and are operated in the current control mode (CCM) because the magnitude and the frequency of the output voltage are tied to the grid voltage. Thus, the discrete state-space equations for the inverter model operating in the CCM can be expressed with sampling time T_s as follows:

$$x_g(k + 1) = A_g x_g(k) + B_{g1} v_g(k) + B_{g2} u_g(k) \tag{12}$$

$$y_g(k) = C_g x_g(k) + D_g v_g(k) \tag{13}$$

where the subscript g represents the inverter model during grid connected operation, k is the discretized present time step, and $x_g(k) = i(k)$ is the state vector; $v_g(k) = [v_{DG}(k + 1) \ v_{DG}(k)]T$ is the exogenous input; $u_g(k)$ is the control signal with $-1 \leq u_g(k) \leq 1$; and $y_g(k) = i_{DG}(k)$ is the output.

$$A_g = 1 - \frac{R}{L_f} T_s, \quad B_{g1} = \begin{bmatrix} 0 & -\frac{T_s}{L_f} \end{bmatrix}, \quad B_{g2} = \frac{V_{dc} T_s}{L_f}$$

$$C_g = 1, \quad D_g = \begin{bmatrix} \frac{C_f}{T_s} & -\frac{C_f}{T_s} \end{bmatrix}$$

The exogenous input $v_g(k)$ can be calculated using state estimation. In this paper, the grid is set as a large power system, which means that the grid voltage is a stable three-phase sinusoidal voltage. Hence, when operating in the CCM, a three-phase sinusoidal signal can be used directly as the exogenous input.

During islanded operation, the inverters will be operated in the voltage control mode (VCM). The voltage of the PCC will be maintained by the inverters when the micro grid is islanded from the grid. As compared to T_s ,

the rate of change of the inverter output current is much slower. Therefore, the following assumption is made when deriving the state-space equations for the inverter operating in the VCM [33]:

$$\frac{di_{DG}}{dt} = 0. \tag{14}$$

Based on the above mentioned assumption, the discrete state space equations of the inverter model operating in the VCM can




Fig:4. Configuration of the proposed controller for the ac/dc converter.

be expressed as follows:

$$x_i(k + 1) = A_i x_i(k) + B_i u_i(k) \tag{15}$$

$$y_i(k) = C_i x_i(k) \tag{16}$$

where the subscript *i* represents the model of the inverter during islanded operation and

$x_i(k) = [i(k) \ vDG(k) \ iDG(k) \ T]^T$ is the state vector; $u_i(k)$ is the control signal with $-1 \leq u_i(k) \leq 1$; and $y_i(k) = vDG(k)$ is the output. During islanded operation, the inverters are required to deliver all the available power from the PMSGs to the loads. Therefore, only the inverter output voltage is controlled and the output current is determined from the amount of available power.

III. CONTROL DESIGN

A. Control Design for the AC/DC Converter

Fig. 4 shows the configuration of the proposed controller for each ac/dc voltage source converter which is employed to maintain the dc output voltage V_{dc} of each converter and compensate for any variation in V_{dc} due to any power imbalance in the dc grid. The power imbalance will induce a voltage error $(V^*_{dc} - V_{dc})$ at the dc grid, which is then fed into a proportional integral controller to generate a current reference i^*_d for i_d to track. To eliminate the presence of high frequency switching ripples at the dc grid, V_{dc} is first passed through a first-order LPF. The current i_q is controlled to be zero so that the PMSG only delivers real power. The current errors

Δid and Δiq are then converted into the abc frame and fed into a proportional resonant (PR) controller to generate the required control signals using pulse-width modulation.

B. Control Design for the DC/AC Inverter

In order for the micro grid to operate in both grid-connected and islanded modes of operation, a model-based controller using MPC is proposed for the control of the inverters. MPC is a model-based controller and adopts a receding horizon approach in which the optimization algorithm will compute a sequence of control actions to minimize the selected objectives for the whole control horizon, but only execute the first control action for the inverter. At the next time step, the optimization process is repeated based on new measurements over a shifted prediction horizon. By doing so, MPC can make the output track the reference at the next step, as well as plan and correct its control signals along the control process. To derive the control algorithm for the inverters, the state-space equations are transformed into augmented state-space equations by defining the incremental variables in the following format:

$$\Delta \xi(k) = \xi(k) - \xi(k - 1) \dots\dots\dots(17)$$

where ξ represents each variable in the inverter model, such as vDG , iDG , i and u as shown in Fig. 3. By defining the incremental variables, the augmented state space model for the inverter model operating in the CCM during grid-connected operation can be expressed as follows:

$$X_g(k + 1) = A_{g_aug} X_g(k) + B_{g1_aug} V_g(k) + B_{g2_aug} U_g(k) \quad (18)$$

$$Y_g(k) = C_{g_aug} X_g(k) \quad (19)$$

$X_g(k) = [\Delta i(k) \ iDG(k)]^T$ is the state vector; $V_g(k) = [-\Delta vDG(k + 2) \ \Delta vDG(k + 1) \ \Delta vDG(k)]^T$ is the exogenous input; $U_g(k) = \Delta u(k)$ is the control signal; and $Y_g(k) = iDG(k)$ is the output.

Similarly, the augmented state-space model for the inverter model operating in the VCM during islanded operation can be expressed as follows:

$$X_i(k + 1) = A_{i_aug} X_i(k) + B_{i_aug} U_i(k) \dots\dots\dots (20)$$

$$Y_i(k) = C_{i_aug} X_i(k) \dots\dots\dots (21)$$

Where

$X_i(k) = [\Delta i(k) \ \Delta vDG(k) \ \Delta iDG(k) \ vDG(k)]^T$ is the state vector; $U_i(k) = \Delta u(k)$ is the control signal; and $Y_i(k) = vDG(k)$ is the output.

For the control of the two augmented models in the CCM and the VCM, the following cost function is solved using quadratic programming in the proposed MPC algorithm [33]:

$$J = (R_s - Y_j)^T (R_s - Y_j) + U^T j Q U_j \dots\dots\dots(22)$$

subject to the constraint $-1 \leq u_j(k) \leq 1$ (23) where R_s is the set-point matrix, Q is the tuning matrix for the desired closed-loop performance, Y_j is the output of either the augmented model in the CCM or VCM (i.e., Y_g or Y_i), U_j is the control signal of either the augmented model in the CCM or VCM (i.e., U_g or U_i). The first part of the cost function is to compare the output of the augmented model Y_j with the reference R_s and to ensure that the output tracks the reference with minimum error. The second part of the cost function is to calculate the weighted factor of the control signal and to ensure that the control signal generated by the MPC algorithm is within the constraints. The quadratic programming will ensure that the optimal solution for the control signal deviation Δu is achieved while minimizing the cost function J . After the control signal u is generated by the MPC algorithm, it will be applied to the dc/ac inverter as shown in Fig. 3.

IV. NUMERICAL SIMULATION ANALYSIS

The simulation model of the proposed dc grid based wind power generation system shown in Fig. 1 is implemented in MATLAB/Simulink.

TABLE I
PARAMETERS OF THE PROPOSED SYSTEM

Parameter	Value
Distribution grid voltage	$v_g = 230$ V (phase)
DC grid voltage	$V_{de} = 500$ V
PMSG stator impedance	$R_s = 0.2 \Omega, L_s = 2.4$ mH
Distribution line impedance	$R_\ell = 7.5$ m $\Omega, L_\ell = 25.7 \mu$ H
Inverter LC filter	$L_f = 1.2$ mH, $C_f = 20 \mu$ F
Converter capacitor	$C = 300 \mu$ F
Converter and inverter loss resistance	$R = 1$ m Ω
Load 1 rating	$P_{L1} = 35$ kW, $Q_{L1} = 8$ kVAr
Load 2 rating	$P_{L2} = 25$ kW, $Q_{L2} = 4$ kVAr

The effectiveness of the proposed design concept is evaluated under different operating conditions when the micro grid is operating in the grid-connected or islanded mode of operation. The system parameters are given in Table I. In practical implementations, the values of the converter and inverter loss resistance are not precisely known. Therefore, these values have been coarsely estimated.

A. Test Case 1: Failure of One Inverter During Grid-Connected Operation

When the micro grid is operating in the grid-connected mode of operation, the proposed wind power generation system will supply power to meet part of the load demand. Under normal operating condition, the total power generated by the PMSGs at the dc grid is converted by inverters 1 and 2 which will share the total power supplied to the loads. When one of the inverters fails to operate and needs to be disconnected from the dc grid, the other inverter is required to handle all the power generated by the PMSGs. In this test case, an analysis on the micro grid operation when one of the inverters is disconnected from operation is conducted.

With each PMSG generating about 5.5 kW of real power, the total power generated by the four PMSGs is about 22 kW which is converted by inverters 1 and 2 into 20 kW and 8 kVAr of real and reactive power respectively. Figs. 5 and 6 show the waveforms of the real and reactive power delivered by inverters 1 and 2 for $0 \leq t < 0.4$ s respectively. For $0 \leq t < 0.2$ s, both inverters 1 and 2 are in operation and each inverter delivers about 10 kW of real power and 4 kVAr of reactive power to the loads. The remaining real and reactive power that is demanded by the loads is supplied by the grid which is shown in Fig. 7. It can be seen from Fig. 7 that the grid delivers 40 kW of real power and 4 kVAr of reactive power to the loads for $0 \leq t < 0.2$ s. The total real and reactive power supplied to the loads is about 60 kW and 12 kVAr as shown in the power waveforms of Fig. 8. The unsteady measurements observed in the power waveforms for $0 \leq t < 0.08$ s are because the controller requires a period of about four cycles to track the power references during the initialization period. As compared to conventional control strategies, it can be observed that the proposed MPC algorithm is able to quickly track and settle to the power reference. This is attributed to the optimization of the inverters through the model-based MPC control.




Fig. 5. Real (top) and reactive (bottom) power delivered by inverter 1.




Fig. 6. Real (top) and reactive (bottom) power delivered by inverter 2.



Fig. 7. Real (top) and reactive (bottom) power delivered by the grid.

Essentially, model-based control schemes are able to take into account the system parameters such that the overall performance can be optimized. At $t = 0.2$ s, inverter 1 fails to operate and is disconnected from the micro grid, resulting in a loss of 10 kW of real power and 4 kVAr of reactive power supplied to the loads. As shown in Fig:5.




Fig. 8. Real (top) and reactive (bottom) power consumed by the loads.




Fig. 9. DC grid voltage.

The real and reactive power supplied by inverter 1 is decreased to zero in about half a cycle after inverter 1 is disconnected. This undelivered power causes a sudden power surge in the dc grid which corresponds to a voltage rise at $t = 0.2$ s as shown in Fig. 9. To ensure that the load demand is met, the grid automatically increases its real and reactive power generation to 50 kW and 8 kVAr respectively at $t = 0.2$ s, as shown in Fig. 7. At $t = 0.26$ s, the EMS of the micro grid increases the reference real and reactive power supplied by inverter 2 to 20 kW and 8 kVAr respectively. A delay of three cycles is introduced to cater for the response time of the EMS to the loss of inverter 1. As shown in Fig. 6, inverter 2 manages to increase its real and reactive power supplied to the loads to 20 kW and 8 kVAr for $0.26 \leq t < 0.4$ s. At the same time, the grid decreases its real and reactive power back to 40 kW and 4 kVAr as shown in Fig. 7 respectively. The power balance in the micro grid is restored after three cycles from $t = 0.26$ s. It is observed from Fig. 9 that the voltage at the dc grid corresponds to a voltage dip at $t = 0.26$ s due to the increase in power drawn by inverter 2 and then returns to its nominal value of 500 V for $0.26 \leq t < 0.4$ s. As observed in Fig. 8, at $t = 0.26$ s, the changes in power delivered by inverter 2 and the grid also cause a transient in the load power.

B. Test Case 2: Connection of AC/DC Converter During Grid-Connected Operation

The most significant advantage of the proposed dc grid based wind power generation system is that it facilitates the connection




Fig:10. Real (top) and reactive (bottom) power delivered by inverter 1.




Fig:11. Real (top) and reactive (bottom) power delivered by inverter 2.

of any PMSGs to the micro grid without the need to synchronize their voltage and frequency. This capability is demonstrated in this case study.

The micro grid operates connected to the grid and PMSG A is disconnected from the dc grid for $0 \leq t < 0.2$ s as shown in Fig. 1. The real power generated from each of the remaining three PMSGs is maintained at 5.5 kW and their aggregated real power of 16.5 kW at the dc grid is converted by inverters 1 and 2 into 14 kW of real power and 8 kVAR of reactive power. As shown in Figs. 10 and 11, each inverter delivers real and reactive power of 7 kW and 4 kVAR to the loads respectively. The rest of the real and reactive power demand of the loads is supplied by the grid as shown in Fig. 12. It can be seen from Fig. 12 that the grid delivers 46 kW of real power and 4 kVAR of reactive power to the loads.

At $t = 0.2$ s, PMSG A which generates real power of 5.5 kW is connected to the dc grid. This causes a sudden power surge at the dc grid and results in a voltage rise at $t = 0.2$ s as shown in the voltage waveform of Fig. 13. At $t = 0.26$ s, the EMS increases the real delivered by each inverter to 10 kW while the reactive power supplied by each inverter remains unchanged at 4 kVAR as shown in Figs. 10 and 11. This causes a momentarily




Fig. 12. Real (top) and reactive (bottom) power delivered by the grid.




Fig:13. DC grid voltage.

dip in the dc grid voltage at $t = 0.26$ s as observed in Fig. 13 which is then restored back to its nominal voltage of 500 V for $0.26 \leq t < 0.4$ s. The grid also simultaneously decreases its supply to 40 kW of real power for $0.26 \leq t < 0.4$ s while its reactive power remains constant at 4 kVAr as shown in Fig. 12.

C. Test Case 3: Islanded Operation

When the micro grid operates islanded from the distribution grid, the total generation from the PMSGs will be insufficient to supply for all the load demand. Under this condition, the SB is required to dispatch the necessary power to ensure that the micro grid continues to operate stably. The third case study shows the micro grid operation when it islands from the grid.

The micro grid is initially operating in the grid-connected mode. The grid is supplying real power of 40 kW and reactive power of 4 kVAr to the loads for $0 \leq t < 0.2$ s as shown in Fig. 14 while each inverter is delivering real power of 10 kW and reactive power of 4 kVAr to the loads as shown in Figs. 15 and 16. At $t = 0.2$ s, the micro grid is disconnected from the distribution grid by the CBs due to a fault occurring in the upstream network of the distribution grid. It can be seen from Fig. 14 that the CBs fully separate the micro grid from the grid in about half a cycle, resulting in zero real and reactive power supplied by the grid for $0.2 \leq t < 0.4$ s. With the loss of power supply from the grid, the power imbalance between the generation and load demand is detected by the EMS. To maintain the stability of the micro grid, the SB is tasked by the EMS to supply real power of 40 kW at $t = 0.26$ s as shown in Fig. 17.




Fig. 14. Real (top) and reactive (bottom) power delivered by the grid.




Fig. 15. Real (top) and reactive (bottom) power delivered by inverter 1.

At the same time, the real and reactive power delivered by each inverter is also increased by the EMS to 30 kW and 6 kVAr as shown in Figs. 15 and 16 respectively. Fig. 18 shows the dc grid voltage where slight voltage fluctuations are observed at $t = 0.26$ s. The initial voltage rise at $t = 0.26$ s is due to the power supplied by the SB while the subsequent voltage dip is due to the increase in power drawn by the inverters.

V. CONCLUSION

In this paper, the design of a dc grid based wind power generation system in a micro grid that enables parallel operation of several WGs in a poultry farm has been presented. As compared to conventional wind power generation systems, the proposed micro grid architecture eliminates the need for voltage and frequency synchronization, thus allowing the WGs to be switched on or off with minimal disturbances to the micro grid operation. The design concept has been verified through various test scenarios to demonstrate the operational capability of the proposed micro grid and the simulation results has shown that the proposed design concept is able to offer increased flexibility and reliability to the operation of the micro grid.



Fig:16. Real (top) and reactive (bottom) power delivered by inverter 2.




Fig:17. Real power delivered by SB.




Fig:18. DC grid voltage.

However, the proposed control design still requires further experimental validation because measurement errors due to inaccuracies of the voltage and current sensors, and modelling errors due to variations in actual system parameters such as distribution line and transformer impedances will affect the performance of the controller in practical implementation. In addition, MPC relies on the accuracy of model establishment; hence further research on improving the controller robustness to modelling inaccuracy is required. The simulation results obtained and the analysis performed in this paper serve as a basis for the design of a dc grid based wind power generation system in a micro grid.

REFERENCES

- [1] M. Czarick and J. Worley, "Wind turbines and tunnel fans," Poultry Housing Tips, vol. 22, no. 7, pp. 1–2, Jun. 2010.
- [2] The poultry guide: Environmentally control poultry farm ventilation systems for broiler, layer, breeders and top suppliers.
- [3] Livestock and climate change
- [4] Farm Energy: Energy efficient fans for poultry production
- [5] A. Mogstad, M. Molinas, P. Olsen, and R. Nilsen, "A power conversion system for offshore wind parks," in Proc. 34th IEEE Ind. Electron., 2008, pp. 2106–2112.