

APPLICATION OF SWEEP FREQUENCY RESPONSE ANALYSIS (SFRA) METHOD TO DETECT TRANSFORMER FAULT

VISHAL M. PIMPALKAR

P. G. Students at Shri Sant
Gajanan Maharaj College of
Engineering, Shegaon-444203

Abstract- Power transformer is the most important device for reliable power system. While working with it, many faults may occur in it. Diagnosis of these faults can be done with lot of techniques. Here in this paper, transformer fault detection by Sweep Frequency Response Analysis (SFRA) technique has been introduced. The SFRA is nothing but monitoring the change occur in the transformer R-L-C network parameter. SFRA measurement can be done by using sweep frequency of the range of 20 Hz to 20 MHz range. These sweep frequencies applied to transformer in healthy and faulty condition. SFRA gives the results in the form of signature curve in both healthy and faulty cases. This obtained signature curve confirms the exact location of fault. This paper presents simulation study of transformer equivalent circuit with implementation of SFRA technique and shows the SFRA results with both healthy and faulty condition.

Keywords- Power transformer, winding deformation, axial and radial deformation, sweep frequency, signature curve, sweep frequency response analysis.

INTRODUCTION

Power transformer is the heart of the electrical power system and it performs a vital role in the area of transmission and distribution [1]. Upon increasing voltage transfer capacity of transformer for transmission, it should have high grade of insulation strength [2]. In general, we generate the power at lower rating and then step up it to higher ratings for transmission by step up transformer. During this action of power transforming, power losses occur.

Number of faults occur in transformer like turn to turn fault, inter turn fault, winding deformation, core deformation, insulation breakdown and short circuit as well. These faults arise due to all day work. Sometimes fault may occur during transportation from manufacturing place to where it has to be installed. During transportation winding and core deforms.

Transformer is the complex structure of resistance, capacitance and inductance networks. When mechanical deformation is occurred inside the transformer, huge force generated in transformer due to current in it. Due to that force winding deforms radially as well as axially. As a result of this deformation, R-L-C parameters get changed with

respect to their previous values.

In SFRA technique we can detect that deformation easily by applying sweep frequency inserted in the winding. If SFRA results are not similar like when transformer is in healthy condition, then it is the condition of fault.

II. SHORT CIRCUIT FORCES

Electrical and mechanical failure in transformer generates the force resulting from short circuits which may damage the transformers. Due to these forces, transformer winding deforms radially and axially. Short circuit symmetrical current is 6 to 7 times that of rated current and sometimes is high up to 15 to 18 times the rated current at peak time [3]. The formula for force acting on current carrying conductor during short circuit condition is,

$$F = BIL \text{ Newton}$$

where, B – Flux density in Tesla

I – Current in Ampere.

L- Length of conductor in meters

So, the resulting forces are very high because they will be increasing in square of current. These forces extend the current carrying conductor radially as well as axially. Due to this mechanical change occur in winding and so impedance value changes.

III. DETECTION TECHNIQUE

For the detection of fault in transformer various techniques are available. But most commonly used are,

- i. Dissolve gas analysis
- ii. Partial discharge method
- iii. Sweep frequency response analysis

i) Dissolve Gas Analysis

The breakdown of insulating materials within transformers and electrical equipment liberate gases within the unit. The distribution of these gases can be related to the type of electrical fault and the rate of gas generation can indicate the severity of fault. The identity of gases being generated by particular unit can be very useful information about fault. The types

of fault depend on what type of gas is extracted from transformer oil.

ii) *Partial discharge method*

Due to improper manufacturing process in insulation design of transformer micro void id formed during the year of service of transformer. Micro void grows to a big cavity with time passes. Due to electromechanical stress potential difference appears across void. This treeing effect occur on the opposite electrodes leads to developing of partial discharge (PD) means conducting path is formed on insulating material surface which causes weak insulation. Means it is the case of insulation failure condition.

PD is important phenomenon which causes degradation of insulating material in transformer winding. There are number of methods which can detect the actual PD location like UHF light emission, chemical method and acoustic emission techniques.

iii) *Sweep frequency response analysis*

This method can give the proper information about an indication of core movement and winding deformation. This method can be done in four steps.

- 1) Measurement in healthy transformer
- 2) Again, Measurement in faulty case of sister transformer of similar rating
- 3) Signature curve of both conditions means healthy and faulty compared.
- 4) If any difference between both cases found means fault occurred.

In this method measurement are performed at frequency ranges varied from 20 Hz to 20 MHz.. It is most effective method of fault detection comparatively to DGA and PD method. As in both cases we can detect fault and in PD method we can detect insulation failure only. But in SFRA method

we can detect number of faults which are related to transformer and also the exact location of fault. So it is more effective than both DGA and PD methods.

IV. SIMULATION RESULTS

The Sweep frequency response analysis method is simulated under MATLAB/Simulink environment. The results found from the same for different cases are explained in this section. These cases are explained below.

Case I. Normal condition:

The transformer model for sweep frequency response analysis is developed in MATLAB/Simulink. The following figure 1 shows the transformer model for healthy condition.

From this model plot for Normal condition is found which is shown in figure 2 below.

The response shows the Normal condition of transformer. This response is found when there is no fault in the transformer. For wide range of frequency, the equivalent circuit of transformer winding includes numerous inductances, resistance and capacitance elements. There are mutual inductive and capacitive coupling between the winding elements, which are effectively determining the SFRA response of winding including multiple resonance and anti-resonances.

The first resonance is occurring at 414 KHz. Beyond this resonance point, inductance of transformer winding dominates. After first resonance point magnetic effect of point tries to increase but winding inductance effect is screened. This process continuously repeats several times so that medium frequency range has a greater number of resonance points.




Figure 1: Transformer model for Normal condition




Figure 2. Simulated SFRA plot for case 1.

After medium frequency range winding inductance effect is completely cancelled due to series and shunt capacitance of windings. The current measured from the waveform is found to be 450.1 A. Further analysis can be considered from first resonance point

Case II: Inter Turn fault

The following figure 3 shows the transformer model for inter turn fault condition. The fault is created in 4th turn of transformer winding. The plot found from this model is shown in figure 4 below.




Figure 3. Transformer model for inter turn fault condition




Figure 4. Simulated SFRA plot for case 2.

From figure 4, we notice that significant waveform displacement occur compared to no fault waveform. The first resonance point occurring at 424 KHz. Also in medium frequency range there is slight waveform displacement compared to Normal condition waveform. But from 2 MHz. to 4. 23MHz.range, big displacement occurs. The current measured at inter turn fault condition is 500.1 A. Compared to Normal condition 50 A hike is observed. Increased current produces an abnormal heat which will affect

transformer insulation and also leads to winding burn out.

Case III: Turn to Turn Fault Condition

The transformer model for turn to turn fault is shown below in figure 5. Here the fault is created between turns 3rd and 4th turn of transformer winding. The plot obtained from this model for turn to turn fault is shown in figure 6.




Figure 5. Transformer model for turn to turn fault condition




Figure 6: Simulated SFRA plot for case 3




Figure 7: Transformer model for change in ground capacitance condition




Figure 8: Simulated SFRA plot for case 4

The plot shown above gives SFRA behavior for turn to turn fault condition. From figure 6 we can notice that significant waveform displacement occurs compared to Normal waveform. Also, these waveforms are compared to turn to turn fault. The first resonance point is observed at 428 KHz. At turn to turn fault condition the waveform obtained gets completely displaced from 1.4417 MHz. to 4.3697 MHz. compared to reference set. The current measured at turn to turn fault condition is 562.7. When compare to Normal condition the increased current is found to be 112.6 A which thermally stress the insulation used in transformer winding. Due to this unexpected thermal stress the insulation is degraded.

Case IV: Change of ground capacitance:

The transformer model for change in ground capacitance is shown above in figure 7 and the plot for this condition is shown in figure 8above. The change of turn to ground capacitance value occurs due to radial displacement of transformer winding. For Normal condition the value of ground

capacitance is 0.011 nF. For analysis purpose choose the turn to ground capacitance value as 52.6 pF. From comparison of figure 2 and figure 8, significant waveform displacement occurs in figure 8. We can notice that waveform of figure 8 is entirely collapse because of capacitance which is inversely proportional to frequency. The first resonance point is appearing at 190 KHz. From 190 KHz. to 221 Khz. waveform displacement occurred. The current found in this case is 450.1 A.

CONCLUSION

The transformer is considered as a heart of power transmission system. During its duties it can undergo some faults like inter turn fault, turn to turn fault, winding deformation, etc. Every transformer winding has its own signature and it is very sensitive as it changes winding parameters. This paper presents simulation of transformer winding fault detection using sweep frequency response analysis. The three faults cases like inter turn fault, turn to turn fault and change in ground capacitance are simulated and are compared with reference Normal condition. On

comparing faulty condition with healthy condition, we notice the change in current value due to change in impedance value of complex network. So this change in current value can detect or diagnose the fault in the transformer winding.

REFERENCES

- [1] Dr. P.M. Joshi, Mrs. Pradnya R. Jadhav, "Study of Transformer Winding Parameters as Deformation Diagnostics Techniques Using FRA Measurement" *ACCT 2011*, pp 373-376.
- [2] Dr. V. Kirubakaran, T. Mariprasath, "Power Transformer Faults Identification using SFRA" *JSER Volume 5, issue 5, may 2014*, pp 81-87.
- [3] Ilampoornam M. K., Vikash M., "Transformer fault detection by frequency response analysis" *IOSRJEEE, volume 1, issue 4, 2012*, pp 27-32.
- [4] G. Joginadham, H. A. Mangalvedekar, A. Venkatasami, "development of networks for SFRA data using circuit synthesis", ICCMD China. 2008.
- [5] Dahlina M. Sofian, Zhongdong Wang, "Interpretation of Transformer FRA Responses— Part II: Influence of Transformer Structure" *IEEE Trans. PowerDel.*, vol. 25, no. 4, Oct. 2010. Doi:10.1109/TPWRD.2010.2050342. (IEEE Transaction)
- [6] Ashok Kumar Yadav, Subash C. Taneja, "Transformer diagnostics testing by SFRA", *The Journal of CPRI*, vol.2, No.2, September 2005, pp 177-185.
- [7] Simon Ryder, "Frequency Response Analysis for Diagnostic Testing of Power Transformers", *Electricity Today Magazine*, Issue June 2001.

