

# Negative Sequence Control of Stability Enhancement of Grid Connected Wind Farms during Grid Faults Using STATCOM

SRAVANI AMBALAM<sup>1</sup> AND MADHURI MODUPALLI<sup>2</sup>

<sup>1,2</sup>Assistant Professor, Srinivasa Ramanujan Institute of Technology, Anantapur, AP, India.

**Abstract:** Now-a-days, wind power generation is a leading one in the family of renewable energy generation because of its several advantages. In these wind farms Squirrel cage Induction Generators are used especially in fixed speed wind turbines directly connected to the grid. Majority of the loads are nonlinear and unbalanced in nature. Due to these unbalanced loads and asymmetrical faults, negative sequence (-ve) components of currents are effected, i.e., negative sequence current increases. These increased negative sequence components will affect induction machine performance and it may damage the insulation of the winding. To mitigate this problem, STATCOM with an effective current controller to limit the negative sequence component of current by current injection is proposed. In this paper, consumption of the proposed system with dynamic load conditions is analyzed using MATLAB/SMULINK.

**Index Terms:** Fixed Speed Induction Generator (FSIG), STATCOM, Negative sequence components.

## I. INTRODUCTION

Day by day, conventional energy resources are decreasing and on the other side power demand is continuously increasing due to the industrialization, electrification or may be due to the little growth in GDP [7]. However and whatever, it is the duty of the government to take steps to bridge the gap. For extracting maximum energy from renewable resources, many optimization methods are being introduced [9]. Among these, wind power generation is the leading one compared to all other sources as a result of its other sources, its cleanness, pollution free nature and availability of high speed winds, its erection is increasing in the world. Basically wind farms are two types, ON shore and OFF shore wind farms [11]. Since the wind speed is more on the ground, power generation of OFF Shore wind farms are high contemplated to ON Shore. Now, extensive research has been progressing on type of generators used in wind generation to extract maximum energy from the wind at all speeds.

The type of generator used is decided based on the type of turbine used. Basically, two types of turbines are available i.e. Variable speed wind turbine and Fixed speed wind turbine. Generally doubly fed induction generator (DFIG) and permanent magnet synchronous generators (PMSG) are widely used for variable speed wind turbines because they offer variety of speed operations. Singly fed induction generators (SFIG) are used for fixed speed wind turbines [19]. In this paper, Fixed speed induction generator (FSIG) is taken in the proposed system and it is directly connected to the grid without using any converters. FSIG wind farm is not capable of providing reactive power, hence to meet the reactive power specifications, some external devices have to be connected in the system. Particularly during abnormal conditions like voltage sags, FSIG will consume more reactive power and may be a chance for the loss of synchronism. From Past few years, the research is being done to find out an effective compensating devise to full fill the reactive power requirements [4] and to increase the fault ride through capability to maintain synchronism with grid. In spite of its restrained capability to indulge voltage and frequency control, fixed speed wind turbine has been used because, wind power plants with type1 (squirrel cage induction generators) wind turbines endow to system frequency support besides accomplishment of maximum efficiency at one appropriate wind speed, for the reason that each and every distinct wind turbine generator is directly connected to the power grid. Among FACTS devices, STATCOM [16] can give effective solution in stability enhancement. STATCOM is one type of shunt active filter and it consists of voltage source besides a converter [3]. It provides reactive power mitigation, dynamic stability improvement and maintains the grid code.




Figure 1: FSIG wind farm integration with STATCOM

The system will work effectively under balanced condition; at faulted and over load condition also it will maintain synchronism up to their capabilities. But, for unbalanced load and unsymmetrical fault conditions, system goes to unbalanced condition leading to the effect on negative sequence components of currents [11]. These effected currents will increase the temperature of the machine inculcating the failure of major and minor insulations [10]. STATCOM control is introduced to control the negative sequence currents by using different current injection methods [1].

Application of STATCOM, coupled to FSIG wind farms is illustrated in this paper. It will control the sequence voltages at fault conditions and improves the consumption of the wind farm. The STATCOM can adequately control the torque ripple and negative sequence

components, at dynamic load conditions for the better performance. Here, 3 $\phi$  symmetry is lost as a result of which the synchronous frame voltage regulator works. The unbalances are inculcated by facilitating separate control loop for +ve and -ve sequence components. This regulator restrains the STATCOM to enhance ride through, without disconnecting from the grid and also injects the -ve sequence components in phase opposition with main cause by which the average of these two reduces neutral currents [21].

## II. PROPOSEDSYSTEM-SPECIFICATIONS

Table 1: Description about grid and transformer

	<i>Grid</i>	<i>HV transformer</i>	<i>MV transformer</i>
Base apparent power	1000.0 MW	100.0 MW	100.0 MW
Rated voltage	110.0 kV	30.0 kV	690.0 V
Stray impedance ( $X_g$ )	0.980 pu	0.050 pu	0.10pu
Resistance ( $R_g$ )	0.020 pu	0.20pu	

The proposed system is depicted in Figure 1 FSIG based wind farm is interfaced directly to grid and STATCOM is connected in shunt. The system parameters are as shown in table 1 and 2 [18].

Table 2: Parameters of Induction Generator and STATCOM

<i>Induction Generator Specifications</i>	
Base apparent power	57.50 MW
Rated active power	50.0 MW
Rated voltage (line to line)	690.0 V
Stator resistance ( $R_s$ )	0.01080 pu
Stator stray impedance ( $X_{ss}$ )	0.1070 pu
Mutual impedance ( $X_h$ )	4.40 pu
Rotor resistance ( $R^1$ )	0.012140 pu
R	0.14070 pu
Rotor stray impedance ( $X^1$ )	0.170 pu
$R\sigma$	3.0s
Compensation Capacitors	
Mechanical time constant H	
<i>STATCOM Specifications</i>	
Rated power	50.0 Mvar
Rated voltage	690.0 V
Line filter $L_{filter}$	0.150 pu
DC voltage $U_{DC}$	1200.0 V
Current capability	1.0 pu

## III. INDUCTION GENERATOR UNDER VOLTAGE DIPP

Positive sequence component of torque and induction machine stator voltage are calculated using [12]. At faulted condition transients in torque will affect the system stability, up to their withstand capacity it remains in synchronism. i.e. for small voltage variations. For high faults torque – slip characteristics were changed highly then voltage drops drastically the system loss synchronism [5]. When the system goes to unbalanced condition the negative sequence components are affected. Then negative sequence component of current increases highly, it will damage the system. The generated negative sequence component of currents can cause torque oscillations at two times of its frequency. From sequence analysis positive sequence component of torque is reduced due to voltage reduction. Then reduction of average voltage will reduce the torque and it affects turbine shaft. The negative sequence components of voltage and torque are compensated by STATCOM.

## IV. STATCOM CONTROL STRUCTURE

STATCOM control consists of reactive power control, outer vector voltage control and inner current controlled in cross structure. The control parameters are calculated in direct axis and quadrature axis components why because PI controller can give better performance when parameters are in synchronous reference frame. Calculation of control gain constants of voltage controller was mentioned in [14] - [16], resonant control is added in the control design. The effected negative sequence components of currents will be controlled by estimating the percentage of effected components comparing with the reference components besides the error components are reduced by PI controller [2]. The structure of the controller is depicted in Figure1. The effected voltage and dc component will be restrained without over voltage control loop of STATCOM control by measuring voltage at PCC. From measured voltage sequence components are calculated then comparison and controlling is performed. Then effected component of current measured from current at PCC, it was controlled by dual actuated PI controllers and it was put the current in the limits.

Induction generators operate with variety of control strategies [18] leading to the clarification of the impact of the -ve sequence voltage compensation which are performed out for analysis beneath the unbalanced grid fault [13]. The purpose of the first and second methods is to diminish the +ve & -ve sequence potential differences respectively. While the respective opposite sequence voltages will remain unchanged.

## V. PURPOSE OF DSOGIPLL

Basically, Phase Locked Loop (PLL) technique is used for the synchronization of the grid in which the potential difference components of the three phase signal of natural reference frame are converted into two phase rotating dq reference frame. For detecting the phase angle of the

three phase systems we use SRF PLL. Specially, the SOGI based PLL are designed to decouple the +ve & -ve sequence components and hence the correlated phase angle for both the sequence components are properly detected.

$$\begin{bmatrix} V_a \\ V_b \\ V_c \end{bmatrix} = \begin{bmatrix} 1 & 0 & 0 \\ -1 & \frac{\sqrt{3}}{2} & 0 \\ -1 & -\frac{\sqrt{3}}{2} & 0 \end{bmatrix} \begin{bmatrix} V_\alpha \\ V_\beta \\ V_0 \end{bmatrix}$$

The sustaining fundamental of the DSOGI PLL is dependent upon the Instantaneous symmetrical component method for the estimation of -ve sequence components of the grid potential difference vectors in the stationary domain. Once the synchronization is done we obtain all the control variables in dc values [21].






Figure 2: SOGI Quadrature signal generator


**VI. RESULTS AND DISCUSSIONS**

The system performance is analyzed from its outputs as shown below. Here, dynamic load conditions are observed, which shows some effect on system performance. Balanced dynamic loads are used that's why the harmonic content will be reduced because the fundamental value goes to increase compared to harmonic component THD will be reduced.





(f) STATCOM currents



(g) P & Q of STATCOM

Figure 3: The above results are the response of the FSIG system under dynamic loading condition

The THD analysis is done under steady load and dynamic load conditions with both the generators working with STATCOM. The system dynamic loads are 15kw are continuously is in on condition, 120 kw of load ON at 0.4s, 143kwofloadONat0.9sand1900wloadoperatedat1.3-1.7s.Theunsymmetricalfaultisappliedat1-1.5s, at this condition STATCOM starts current injection, the STATCOM power injections are shown in Figure 3(g). The voltage variations at PCC with STATCOM are observed from Figure3(b). Non-linearity of electrical equipment produces distortion of fundamental sine wave associated with a phenomenon called harmonic disturbance causing raised currents, power losses and probable damaging over heat in equipment, Limitations in communication circuits. Restrictions on the Total Harmonic Distortion (THD) along with specific harmonics [8] are set up by the specific standards of Harmonics. Variable speed wind turbines with a specified switching frequency uses Power electronic converters performing in a peculiar mode as on and off, shifts the harmonics to higher frequency by which they can be easily eliminated with the help of small filters. Novel wind turbines are used to meet the standards of harmonics practically.

Table 3: THD at different loading conditions

Load condition	% of THD
Steady load condition	5.77
Dynamic load condition	4.090

**VII. CONCLUSION**

The grid Integration of wind farms can give wide area of operation compared to Islanded micro grid operations. The STATCOM incorporation with wind farm can give better performance and the fault rides through potentiality of wind farms are increased. The STATCOM with effective current control can keep negative sequence component of current in the limits, incorporated with other voltage and reactive power controllers. System performance with STATCOM under dynamic load condition is improved compared to steady load condition. The %THD in fundamental wave is reduced from 5.79 to 4.09. Finally system stability is enhanced with introducing STATCOM in wind farm grid integration.

**References**

- [1] Christian Wessels, Nils Hoffmann, Marta Molinas, Friedrich Wilhelm Fuchs “StatCom Control at Wind Farms With Fixed-Speed Induction Generators Under Asymmetrical Grid Faults” *IEEE Transaction on Industrial Electronics*, Vol. 60, No. 7, July 2013.
- [2] C. Hochgraf and R. Lasseter, “STATCOM controls for operation with unbalanced voltages,” *IEEE Trans. Power Del.*, Vol. 13, No. 2, pp. 538-544, Apr.1998.
- [3] D.SotoandT. Green,“A comparison of high-power converter topologies for the implementation of FACTS controllers,”*IEEE Trans. Ind. Electron.*, Vol. 49, No. 5, pp. 1072-1080, Oct. 2002.
- [4] Y. Cheng, C. Qian, M. Crow, S. Pekarek, and S. Atcitty, “A comparison of diode-clamped and cascaded multilevel converters for a statcom with energy storage,” *IEEE Trans. Ind. Electron.*, Vol. 53, No. 5, pp. 1512-1521, Oct.2006.
- [5] L.Xu,L.Yao,andC.Sasse,“ComparisonofusingSVCandstatcomforwindfarmintegration,”in*Proc.Int.PowerCon*,Oct. 2006, pp. 1-7.
- [6] C. Han, A. Huang, M. Baran, S. Bhattacharya, W. Litzemberger, L. Anderson, A. Johnson, and A.-A. Edris, “Statcom impactstudyontheintegrationofalargewindfarmintoaweaklooppowersystem,”*IEEETrans.EnergyConvers.*,Vol. 23, No. 1, pp. 226-233, Mar.2008.
- [7] J. Dannehl, C. Wessels, and F. W. Fuchs, “Limitations of voltage oriented PI current control of grid-connected PWM rectifiers with LCL filters,” *IEEE Trans. Ind. Electron.*, Vol. 56, No. 2, pp. 380-388, Feb.2009.
- [8] M. Tsili and S. Papathanassiou, “A review of grid code technical requirements for wind farms,” *IET Renewable Power Gener.*, Vol. 3, No. 3, pp. 308-332, Sep.2009.
- [9] Chen,Z, :”Wind farm-A power source in future power systems”, *Renewable and Sustainable Energy Reviess*,2009
- [10] M. Ali and B. Wu, “Comparison of stabilization methods for fixed speed wind generator systems,” *IEEE Trans. Power Del.*, Vol. 25, No. 1, pp. 323-331, Jan.2010.

- [11] M. Molinas, J. Suul, and T. Undeland, "Extending the life of gear box in wind generators by smoothing transient torque with STATCOM," *IEEE Trans. Ind. Electron.*, Vol. 57, No. 2, pp. 476-484, Feb.2010.
- [12] M. Liserre, R. Cardenas, M. Molinas, and J. Rodriguez, "Overview of multi-MW wind turbines and wind parks," *IEEE Trans. Ind. Electron.*, Vol. 58, No. 4, pp. 1081-1095, Apr.2011.
- [13] N. Hoffmann, L. Asiminoaei, and F. W. Fuchs, "Online grid-adaptive control and active-filter functionality of PWM- converters to mitigate voltage unbalances and voltage-harmonics a control concept based on grid impedance measurement," in *Proc. IEEE ECCE*, Sep. 2011, pp. 3067-3074.
- [14] C. Wessels, F. Fuchs, and M. Molinas, "Voltage control of a statcom at a fixed speed wind farm under unbalanced grid faults," in *Proc. 37th IEEEIECON*, Nov. 2011, pp. 979-984.
- [15] BhanuRaghavaPrakash.R,Trinath.K,Sundeeep,"GridFaultAnalysisofUnbalancedLoadedDFIG,"*2011International Conference on Applied Physics andMathematics*.
- [16] H. Mahmood and J. Jiang, "Modeling and control system design of a grid connected VSC considering the effect of the interface transformer type," *IEEE Trans. Smart Grid*, Vol. 3, No. 1, pp. 122-134,Mar.2012.
- [17] K. Samrajyam, and R. B. R. Prakash, "Optimal location of STATCOM for reducing voltage fluctuations" *International journal of Modern Engineering Research*, Vol. 2, Issue 3, 2012May-June.
- [18] P. Ramya Krishna and R. B. R. Prakash, "Series Voltage Compensation Using UPQC For FSIG Wind Turbine Low- Voltage Ride-Through Solution" *International journal of Modern Engineering Research*, Vol. 2, Issue 3, 2012 May- June.
- [19] Christian Wessels, Student Member, Nils Hoffmann, Marta Molinas, and Friedrich Wilhelm Fuchs, IEEE, "STATCOM control at wind farms with Fixed-Speed Induction Generators under Asymmetrical Grid Faults" *IEEE TRANSACTIONSONINDUSTRIALELECTRONICS*, Vol.60,No.7, JULY2013.
- [20] Krishna Manjusha Kondapiand R.B.R. Prakash, "Stability Enhancement of Doubly Fed Induction Generator with Virtual Resistance for Grid Disturbances", *Indian Journal of Science and Technology*, Vol. 8 (17), August2015.
- [21] Ambalam Sravani and R.B.R. Prakash, "Negative Sequence Components Compensation using Statcom to Enhance Stability of Wind Farms During Grid Faults", *IJCTA*, 10(5), pp. 1-10.

