



# Heat Transfer & Pressure Drop In A Circular Grooved Tubewith Rectangular Copper Fin –A Review

Ashish Ranjan<sup>1</sup>, Dr Ajay Kumar Singh<sup>2</sup>, Prof. Deepak Patel<sup>3</sup>

1. Research scholar, Department of Mechanical Engineering, Radharaman Institute of Technology & Science, Bhopal (M.P.)
2. Prof & Head, Department of Mechanical Engineering, Radharaman Institute of Technology & Science, Bhopal (M.P.)
3. Asst. Prof. Department of Mechanical Engineering, Radharaman Institute of Technology & Science, Bhopal (M.P.)

**Abstract:-** The plate Fin-and-cylinder heat exchangers are perhaps the most well-known kind of hotness exchanger that are broadly utilized in assortment modern applications like space warming, refrigeration, cooling, power stations, compound plants, petrochemical plants, petrol treatment facilities, flammable gas handling, avionic business and sewage treatment. Diminish the size, weight and improve the hotness move pace of hotness exchanger. Blade and-cylinder heat exchangers with various directions are utilized to work on the warm exhibition. This survey is to assist with seeing how every referenced boundaries effect on progress of warm performance. After contemplated of various exploration papers, I found novel plan to improve the warm exhibitions of counter to cross stream by utilizing air cooled heat exchanger [ACHE] process. In air cooled heat exchanger [ACHE] process are utilizing winding scored aluminum concentric cylinder and rectangular copper balances. Heated water will be stream in winding notched aluminum tube and rectangular balances will be fitted on tube.

**Keywords-** Rectangular fin, pressure drop, turbulent flow, Air cooled heat exchanger [ACHE], Internal grooving.

## I. INTRODUCTION

A heat exchanger is worked for proficient hotness move starting with one medium then onto the next. The media might be isolated by a strong divider to forestall blending or they might be in direct contact. They are generally utilized in space warming, refrigeration, cooling, power stations, substance plants, petrochemical plants, petrol treatment facilities, flammable gas handling, aeronautic trade and sewage treatment. The exemplary illustration of a hotness exchanger is found in a gas powered motor in which a circling liquid known as motor coolant courses through radiator loops and wind streams past the curls, which cools the coolant and warms the approaching air. Blades are surface expansions broadly utilized in various sorts of hotness exchangers for expanding the pace of hotness move among a strong surface and encompassing liquid Fins are surface augmentations generally utilized in various kinds of hotness exchangers for expanding the pace of hotness move among a strong surface and encompassing liquid. Tentatively looked at heat move improvement and tension drop in twofold line inside finned tube heat exchanger by utilizing nano liquids and contrasted these outcomes and plain cylinder heat exchanger. Results shows that the hotness move rate is 80–90% a larger number of than plain cylinder heat exchanger.often mathematically altered blades are joined, which other than expanding the surface region thickness of the hotness exchanger, likewise further develop the convection heat move coefficient. A few instances of such improved surface smaller centers incorporate Offset-strip blades, Louvered balances, Wavy balances, Plain balances and Pin balances. Of these, wavy balances are especially appealing for their effortlessness of assembling, potential for improved warm water driven execution and simplicity of utilization in both plate-blade and cylinder balance type exchangers. Upgrade of hotness move can lessen the size of hotness exchangers, decreasing in pressure drop give higher hotness move productivity, and yield reserve funds of working expenses and materials. The upgrade of hotness move is fundamentally significant in modern applications, for example, process cooling, refrigeration, compound handling, air partition, and so on Balances or broadened surfaces assume a significant part to increase the pace of hotness move. In circumstances of consolidated conduction-convection impacts, contingent upon the application, different kinds of

increased hotness move surfaces like rectangular, three-sided, trapezoidal balances, Pin balances, wavy blades, offset strip balances, louvered balances and punctured balances are utilized. It's obviously true that any upgrade procedure will present extra liquid tension drop, and frequently the proportion of strain drop increment is bigger than that of hotness move improvement. Also the hotness move rate diminishes alongside the tallness of the blade, to defeat the previously mentioned issues different kinds of balance game plans and balance calculations are utilized.

## II. LITERATURE REVIEW

**Chang, Tae-Hyun et al. [1]** studied thermal performance and pressure drop are considered as major factors. Both, thermal performance and pressure drop are dependent on the path of fluid flow and types of baffles in different orientations respectively. Increasing the complexity of baffles enhances heat transfer which also results in higher pressure drop which means higher pumping power is required. This reduces the system efficiency. This paper presents the numerical simulations carried out on different baffles i.e. single segmental, double segmental and helical baffles. This shows the effect of baffles on pressure drop in shell and tube heat exchanger. Single segmental baffles show the formation of dead zones where heat transfer cannot take place effectively. Double segmental baffles reduce the vibrational damage as compared to single segmental baffles. The use of helical baffles shows a decrease in pressure drop due to the elimination of dead zones. The less dead zones result in better heat transfer. The lower pressure drop results in lower pumping power, which in turn increases the overall system efficiency. The comparative results show that helical baffles are more advantageous than other two baffles.

**Afzal et al. [2]** experimentally studied the optimum spacing between grooved tubes is reported in this paper. Two grooved tubes having pitch of 10 mm and 15 mm and a plain tube were considered for the heat transfer analysis. The spacing between two tubes with same pitch was varied from 10 mm to 35 mm with a step size of 5 mm. Velocity of air flowing over the tube surfaces was changed from 0.4 m/s to 1 m/s using a blower fan. Based on Nusselt number ( $Nu$ ) the optimum spacing between the tubes was decided. The optimum spacing between grooved tubes of pitch 10 mm and 15 mm was compared with that of plain tubes. From the experimental analysis it was noticed that with increase in air velocity (increase in Reynolds number) the tube surface temperature reduced irrespective of any tube considered.  $Nu$  increased with increase in air velocity for all the tubes. The important conclusion drawn from the present study was that, there exists a limiting spacing (optimum) between the tubes above which no change in  $Nu$  was observed. Spacing of 30 mm was found to be the optimum spacing between the tubes irrespective of its surface geometry modifications.

**S Basavarajappa et al. [3]** Experiments investigated the effect of nanofluid on turbulent heat transfer and pressure drop inside concentric tubes. Water and  $\text{SiO}_2$  with mean diameter of 30 nm were chosen as base fluid and nano-particles, respectively. Experiments were performed for plain tube and five roughened tube with various heights and pitches of corrugations. Results show that adding the nano-particles in tube with high height and small pitch of corrugations augments the heat transfer significantly with negligible pressure drop penalty. It is discussed on relative Nusselt number and thermal performance of heat exchanger.

**Jie Qu et al. [4]** discussed the heat transfers of PCM and enhance the thermal performances of PCM used two type of novels are 3D-OHPs (4 layers 3D-OHP and 3 layers 3D-OHP) and PCM coupled with multiple 2D-OHPs. Phase change materials (PCM) have been mostly use in thermal managements because its have high latent heat and low price. Phase change materials are use Oscillating heat pipes(OHP) and effective thermal transfer devices for heat transfer. Its due to enhance the thermal performances. In this experimental manuscript both novels 3D-OHPs and regular OHPs are hired for the PCM thermal performance. By knowing this research paper Results shows that paraffin wax/3D-OHP systems are needed extra times for finally melting of paraffin wax than paraffin wax/OHPs system. In the solidification process two systems are performed better than simply paraffin wax. The solidification times of the pure paraffin wax and paraffin wax/4-layers 3DOHP are taken only 0.29 times where as the paraffin wax/4 OHP systems are 0.48 times taken. Such as the paraffin wax/3D-OHP systems are superior performances.

**Hassan Jafari Mosleh et al. [5]** experimentally and numerical investigated the pulsating heat pipes(PHPs) as substitutes for fins in a representative air-cooled heat exchanger(ACHE).Because of low temperatures difference between the cooling air and internal airflow. In which R134a was selected as the best working fluid from the heat transfer stand point. Than PHPs are filled with working fluid,the coefficient of heat transfer and temperature difference have been increased. In this condition the performances of the PHP-tubes are noted without working fluids are similar to the fin tube. When the axial fans are stopped due to small gap between the fins and produce poor thermal performances of the fin. By knowing this research paper results shows that using PHPs instead of fins improves heat transfer efficiency. In which Firstly fins and PHP-tubes are tested without any exterior flow over the main tubes and the tests are conducted in natural convection situations.

**Jian Wang et al. [6]** experimentally studied the heat transfers and flow individuality of the three new finned copper head heat sinks are subjected to the impingement chilled by rectangular slot jet and axial fan. These experimental process are used for the fast development of electronic devices has imposed higher requirements for thermal supervision and cooling technology. In this experiment taken effect of heat sink heights (H, 15, 30, 45, 60 mm), the pore density of the inserted copper head (PPI, 10, 20, and 30) and the gas flows

Reynolds number ( $Re$ , varying from 2053- 12737) are scientifically investigated. Where are two types of conventional fin heat sink with 8 and 22 fins but without copper heads are tested for judgment. Such as Experimental results expose that inserting copper heads are completely enhance the thermal performances of finned heat sinks. Finned copper foams and conservative heat sinks with the same numbers of fin but finned copper foams are better heat transfer performance. By knowing this experimental research paper, when the height of heat sinks decreases than pressure drop for all five kinds of heat sinks increases.

**De-Shau Huang et al. [7]** experimentally and numerically studied the automotive headlights using for heat indulgence. In this experiment, we required to enhance the efficiency of heat transfer of LED take on fins with a grooved heat pipe on the heat sinks. ANSYS Fluent software is used just before model of the heat transfer mechanisms and aid in the design of heat pipes and heat sinks. The temperature distribution of the LED head lights are computer-generated for various material of the heat sinks and printed circuit board (PCB), and fins are designed with a heat pipes. It was found increases the coefficient of thermal conductivity of the substrate due to decreases in the LED junction temperatures, however higher thermal efficiency was not essentially enough. In this trial demonstrated that the reconciliation of 76-mm-since quite a while ago furrowed warmth channels with a compelling warm conductivity of 6000 W/(m•K) and 2-mm arduous plate heat dissemination balances on the warmth sink with an AlN Ceramic having a 180 W/(m•K) demonstrated successful in scattering heat from powerful LED headlights inside a profoundly constrained space. By knowing this research paper enhance the coefficient of thermal conductivity of the substrate due to results are decreases in the LED junction temperature. However the higher thermal efficiency are not necessarily sufficient.

**Hai Wang et al. [8]** investigated the thermal performance of the oscillating heat pipes(OHP) designed, temperature distribution and explanation profiles of LED array are experimentally tested and evaluated. In this experiment the thermal management of high-powered LED chips are designed and fabricated, where are the tubular oscillating heat pipes(OHP) with sintered copper particles(SCPs) are inside of the flat plate evaporator. The thermal performances of designed OHP, temperature giving out and explanation profiles of LED array were experimentally tested and evaluated. A low substantial ratio of 30% are preferred for the designed OHP practical in high-power LED cooling. By knowing this research paper, heat sink of tubular OHP with SCPs inside the flat plate evaporators are developing for the cooling of high power density array. The performances of LED heat sinks are experimentally investigation of the effect of evaporators with SCPs, power input, inclination angle and filling ratio. When the addition of the sintered copper particles(SCPs) with oscillating heat pipes(OHP) due to appreciably enhance the vapor bubble generation rate. The temperature division of the LED array at input power and low filling ratio have different inclination angles are instant or less than 70 °C. The filling ratio affect the OHP put in place performance. The low filling ratio are ideal for the OHP practical because the thermal management of high-power LED. In this experimental setup , the temperature of LED array are inversely proportional to the explanation intensity.

**Demis Pandelidis et al. [9]** studied the sloping evaporative exchangers are worked as heat recovery units, given configurations are counter flow and cross flow. In this experiment presented analysis are accepted out with particular importance on the condensation process that occurs in the product air channels of the exchangers. In which various aspects are related to the water vapor condensation and manage. Which aspects are taken in the classification factors that control the condensation process. Those analyzing factors are forced on dissimilar IEC exchanger arrangement. There are a variety of inlet parameter and operating condition for judgment of the counter and cross flow exchangers. Those performed analysis are based on numerical simulations with mathematical e-NTU models of heat and mass transfer. By knowing this research paper found result showed that the counter flow configuration has high reasonable and latent cooling potential than the cross flow unit. The technical limitation of counter-flow configuration due to the cross flow exchangers are achieved higher Energy Efficiency Ratio and lower investment cost. Whenever, the structure of the counter-flow design that requires supplementary input or output branch of the results are increased size of the counter flow components and higher pressure drop balance with the cross flow exchangers.

**Lei Wang et al. [10]** presented a mathematical model that combined the law of energy conservation and the principle of the irreversible thermodynamic theory. In this investigation the wet bulb indirect evaporative cooling (IEC) achieved through M-Cycle is a difficult thermodynamic process. Heat and mass transfer for advance understanding occurs in a dew point indirect evaporative air cooler with M-Cycle counter flow configuration. The research paper are represented mathematical model. The model comprising of various energy, mass and entropy equations are uses to take out the study of the dew point air cooler below various operational and structural conditions. The entropy creation numbers are establish to be a show potential indicator for the optimized designs. The mutual analysis are energy efficiency and thermodynamic irreversibility of the intention IEC system. The optional average air velocities of dry channels should be less than 1.0m/s. In this experimental setup the channel length should be in range of 1e1.75m and channel gap should be controlled to 3e5 mm. Whereas the working to intake air ratio must be around 0.3e0.4. By knowing this research paper, for better and advance understand of the heat and mass transfers are occurred in a dew point indirect evaporative air cooler with M-Cycle counter flow configuration. Based on this experimental study has been proved that the entropy production numbers are used for the useful parameters in the optimization designs of the HMX for a dew point IEC.

**Nithiyesh Kumar et al. [11]** experimentally studied the flow over array of trapezoidal-ribs transversely placed on the wider bottom surface of the rectangular passage. It is intended to study the profound impact of taper angle variation ( $0$  to  $20^\circ$ ) on the flow mechanism, and subsequently on heat transfer improvement. The local and augmentation heat transfer patterns have been investigated using liquid crystal thermography (LCT). Further, the aerodynamic characteristics, in a module between seventh and eight ribs, have been obtained using particle image velocimetry (PIV) for understanding the flow physics. Existence of large- and small-scale coherent structures within the detached shear layer zone have been confirmed and further explained by means of critical points. As compared to square rib, trapezoidal rib provides higher heat transfer rate just downstream of the rib, which is observed to be in line with the fluid flow results.

**Pengxiao Li et al. [12]** experimentally investigated the thermal performance and exergy analysis in an internally grooved (IG) tube fitted with triangular cut twisted tape insert consisting of alternate wings (TCTT). The analysis is carried out with TCTT for different twist ratio,  $y = 3.5, 5.3$  and  $6.5$  with attack angle,  $\beta = 45^\circ$  and  $90^\circ$ . The investigations were performed in turbulent regime, with Reynolds number ranging from  $3000$  to  $14,000$ . The thermal and exergy efficiencies were used to evaluate the overall performance of the heat exchanger, by considering exergy gain and exergy lost. The experimental results reveal that, both the thermal efficiency and exergy efficiency of the IG tube equipped with TCTT were found to be increased up to  $1.12$  and  $1.85$  times, respectively, than those that with plain twisted tape (PTT). In this study, the IG tube with TCTT of  $y = 3.5$  and  $\beta = 90^\circ$  achieved maximum PER and exergetic efficiency of  $1.35$  and  $0.634$ , respectively, at Reynolds number  $3000$ . The empirical correlations were developed from experimental results, to predict the Nusselt number (Nu), friction factor (f) and Performance enhancement ratio ( $\eta$ ).

**Pankaj N. Shirao et al. [13]** experimentally studied the mean Nusselt number, friction factor and thermal enhancement factor characteristics in a circular tube with different types of internal threads of  $120$  mm pitch under uniform wall heat flux boundary conditions. In the experiments, measured data are taken at Reynolds number in range of  $7,000$  to  $14,000$  with air as the test fluid. The experiments were conducted on circular tube with three different types of internal threads viz. acme, buttress and knuckle threads of constant pitch. The heat transfer and friction factor data obtained is compared with the data obtained from a plain circular tube under similar geometric and flow conditions. The variations of heat transfer and pressure loss in the form of Nusselt number (Nu) and friction factor (f) respectively is determined and depicted graphically. It is observed that at all Reynolds number, the Nusselt number and thermal performance increases for a circular tube with buttress threads as compared with a circular tube with acme and knuckle threads. These are because of increase in strength and intensity of vortices ejected from the buttress threads.

**Kadir Bilen et al. [14]** experimentally studied the surface heat transfer and friction characteristics of a fully developed turbulent air flow in different grooved tubes. Tests were performed for Reynolds number range  $10,000$ –  $38,000$  and for different geometric groove shapes (circular, trapezoidal and rectangular). The ratio of tube length-to-diameter is  $33$ . Among the grooved tubes, heat transfer enhancement is obtained up to  $63\%$  for circular groove,  $58\%$  for trapezoidal groove and  $47\%$  for rectangular groove, in comparison with the smooth tube at the highest Reynolds number ( $Re = 38,000$ ). Correlations of heat transfer and friction coefficient were obtained for different grooved tubes. In evaluation of thermal performance, it is seen that the grooved tubes are thermodynamically advantageous ( $N_s, a < 1$ ) up to  $Re = 30,000$  for circular and trapezoidal grooves and up to  $Re = 28,000$  for rectangular grooves. It is observed that there is an optimum value of the entropy generation number at about  $Re = 17,000$  for all investigated grooves.

**P.Bharadwaj et al. [15]** experimentally determined the pressure drop and heat transfer characteristics of flow of water in a 75-start spirally grooved tube with twisted tape insert are presented. Laminar to fully turbulent ranges of Reynolds numbers have been considered. The grooves are clockwise with respect to the direction of flow. Compared to smooth tube, the heat transfer enhancement due to spiral grooves is further augmented by inserting twisted tapes having twist ratios  $Y = 10.15, 7.95$  and  $3.4$ . It is found that the direction of twist (clockwise and anticlockwise) influences the thermo-hydraulic characteristics. Constant pumping power comparisons with smooth tube characteristics show that in spirally grooved tube with and without twisted tape, heat transfer increases considerably in laminar and moderately in turbulent range of Reynolds numbers. However, for the bare spiral tube and for spiral tube with anticlockwise twisted tape ( $Y = 10.15$ ), reduction in heat transfer is noticed over a transition range of Reynolds numbers.

**Nakaso K et al. [16]** studied the heat transfer in a shell-and-tube heat exchanger using sheet fins is numerically investigated. Heat and mass transfers in the heat exchanger are modeled under steady state to estimate the heat transfer rate and the pressure drop for various geometries of the heat exchanger. Based on the numerical results, the Nusselt number and pressure drop are formulated for practical applications. For convenience, similar expressions to those of conventional shell-and-tube heat exchangers, that is, the functions of dimensionless numbers such as the Reynolds number, are derived. In these equations, the geometry of the heat exchanger, fin efficiency, and contact thermal resistance are included as major factors. On formulating the equation for the overall heat transfer rate, it is found that the heat transfer coefficient for the heat exchanger with a fin does not correspond to the combination of the heat transfer coefficient of bare tube surface and the fin. This is because the heat exchange area is substantially limited especially at the narrow space between the tube and the fin. A correction factor for the substantial heat transfer area is therefore introduced. These formulated equations are helpful for installing sheet fins in manufactured heat exchangers. Using the formulated equations, effective conditions to enhance heat transfer rate by the fin are established, taking into account the increase in pressure drop.

**Park K T et al. [17]** experiments studied the thermal resistances of heat sinks with cross-cut branched fins on horizontal cylinders. The experiments were conducted for several numbers of fin, heights of fins, and heat inputs. From the experimental data, the Nusselt number correlation for Rayleigh numbers of 190000–1000000, fin heights of 10–30 mm, and fin numbers of 9–36 is proposed. Using the suggested correlation, the fin thickness and fin number for maximizing the thermal performance are obtained. Finally, it is demonstrated that the optimal heat sink with cross-cut branched fins on a horizontal cylinder has 26 % lower thermal resistance than that of a conventional heat sink with plate fins.

**Bayram Sahin et al. [18]** Study design parameter of a heat sink on which hollow trapezoidal baffle is mounted on the base surface. This experimental design is used Taguchi method. Where Nusselt numbers and friction factors are considered as performance parameter. In which orthogonal arrays are selected as investigational plan for the six parameters: the curve angles( $\alpha$ ), the inclination angle ( $\beta$ ), the baffle heights(H), the baffle lengths(L), the baffle width(S) and Reynolds numbers. First of each goal has been optimized individually and after that all the goals have been optimized together. The baffle lengths(L) are found on the friction factor. The baffle length will in flow direction. Where are the best parameters on the exchange warmth is Reynolds number. The result showed that the heat transfer was obtained at  $Re=17,000$ ,  $H=36$  mm,  $L=45$  mm,  $S=26$  mm,  $\alpha=0^\circ$ ,  $\beta=0^\circ$ . It can be conclude higher heat transfer rates are achieved with lower pressure drop.

### III. OBJECTIVES

- To evaluate the heat transfer rate of simple tube air cooled heat exchanger with rectangular copper fins and air cooled heat exchanger having internal circular grooving at different pitches along with rectangular copper fins.
- To evaluate the efficiency of fins and overall fin effectiveness.
- To evaluate the properties of the fluid (likes pressure loss, velocity, Reynold Number, Prandtl Number etc.) inside the aluminium tube for four setup viz.
- Simple tube air cooled heat exchanger with rectangular copper fins and three air cooled heat exchanger having internal circular grooving at different pitches along with rectangular copper fins.
- To evaluate the effectiveness of air cooled heat exchanger.

### IV. EXPECTED METHODOLOGY

From the above section of literature review we can analyzed the present era research in air cooled heat exchanger, hence we are mainly focus on the experimental and comparative analysis along with the study on different parameters of heat exchangers, with a counter to cross-flow technique using with and without an internally circular grooved aluminium concentric tube attached with rectangular copper fins forced convection ACHE. At first we select the material and dimensions of tube and grooving.

### REFERENCES

- [1] Chang, Tae-Hyun, Lee, Kwon-Soo, Chang, Ki-Won, Kim, Sang Min, & Lee, Chang-Hoan, Heat transfer characteristics of a short helical plate in a horizontal circular tube, *Journal of Mechanical Science and Technology*, 33(8), 3613-3620. 2019.
- [2] Afzal, A., Mohammed Samee, A.D., Abdul Razak, R.K, Optimum spacing between grooved tubes: An experimental study. *J Mech Sci Technol* 34, 469–475, 2020.
- [3] S Basavarajappa, G Manavendra and S B Prakash, “A review on performance study of finned tube heat exchanger”, *Journal of Physics: Conference Series*, Vol. 1473, No. 1, 2020.
- [4] Jie Qu et al., Experimental investigation on thermal performance of phase change material coupled with three-dimensional oscillating heat pipe (PCM/3DOHP) for thermal management application, *International Journal of heat and Mass Transfer*, VOL-129, PP: 773–782, 2019.
- [5] Hassan Jafari Mosleh et al., Experimental and numerical investigation of using pulsating heat pipes instea of fins in air-cooled heat exchangers, *Energy Conversion and Management*, VOL-181, PP:653–662 , 2019.
- [6] Jian Wang et al., Experimental investigation of heat transfer and flow characteristics in finned copper foam heat sinks subjected to jet impingement cooling, *Applied Energy*, VOL-241 ,PP: 433–443, 2019.
- [7] De-Shau Huang et al, Design of fins with a grooved heat pipe for dissipation of heat from high powered automotive LED headlights, *Energy Conversion and Management* ,VOL-180 ,PP: 550–558, 2019.
- [8] Hai Wang et al.Heat transfer performance of a novel tubular oscillating heat pipe with sintered copper particles inside flat-plate evaporator and high-power LED heat sink application, *Energy Conversion and Management*, VOL-189 ,PP:215–222, 2019.

- [9] Demis Pandelidis et al., Performance comparison between counter- and cross-flow indirect evaporative coolers for heat recovery in air conditioning systems in the presence of condensation in the product air channels, *International Journal of Heat and Mass Transfer*, VOL-130, PP: 757–777, 2019.
- [10] Lei Wang et al., Optimization of the counter-flow heat and mass exchanger for M-Cycle indirect evaporative cooling assisted with entropy analysis, *Energy*, VOL-171, PP: 1206-1216, 2019.
- [11] Nithiyesh Kumar, C, Ilangkumaran, M. “Experimental study on thermal performance and exergy analysis in an internally grooved tube integrated with triangular cut twisted tapes consisting of alternate wings”, *Heat and Mass Transfer*, Vol 55, 2019.
- [12] Pengxiao Li, Peng Liu, Zhichun Liu, Wei Liu “Experimental and numerical study on the heat transfer and flow performance for the circular tube fitted with drainage inserts”.*International Journal of Heat and Mass Transfer* Volume 107, 2017.
- [13] Pankaj N. Shrirao, Rajeshkumar U.Sambhe, Pradip R.Bodade, “Convective Heat Transfer Analysis in a Circular Tube with Different Types of Internal Threads of Constant Pitch”.*International Journal of Engineering and Advanced Technology (IJEAT)*, Volume-2, Issue-3, 2013.
- [14] Kadir Bilen, Murat Cetin, Hasan Gul, Tuba Balta, “The investigation of groove geometry effect on heat transfer for internally grooved tubes. *Applied Thermal Engineering*, Volume 29, Issue 4, 2009.
- [15] P. Bharadwaj, A.D. Khondge, A.W. Date, “Heat transfer and pressure drop in a circular grooved tube with twisted tape insert” *International Journal of Heat and Mass Transfer*, Volume 52, Issues 7–8, 2009.
- [16] Nakaso K, Mitani H and Fukai J Convection heat transfer in a shell-and-tube heat exchanger using sheet fins for effective utilization of energy *International Journal of Heat and Mass Transfer* 82 581–591, 2015.
- [17] Park K T, Kim H J and Kim D K, Experimental study of natural convection from vertical cylinders with branched fins *Experimental Thermal and Fluid Science* 54 29–37, 2014.

